

SUB : “ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT”

Sl. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
1	Section V	51	Bill of Quantities(BOQ)	In the BOQ projector screen is not mentioned.	Existing Projector screen will be used.
2	2.3(v)	19	Audio recorder with 320GB memory, Panasonic make, model: TH-59.	Audio Recorder – Panasonic TH -59 is declared end of life by the OEM. Alternate model like- Aver media is available.	AVER media is acceptable.
3	2.4(iii)	21	Providing and fixing Interface switching as per the following specifications: a) This Scaler will take 2 VGA and 10 HDMI which can be scaled and switched Switcher to Switch between VC & Presentation - 4 input / 2 output - Milestone make - 1 nos; b) Distribution Amplifier - 1:4 HDMI Distribution Amplifier - Milestone make - VM-4HN - 1 nos	In fixing Interface switching- Mentioned Milestone make - VM- 4HN - the model mentioned is of Kramer make. We suggest to use Kramer make as its performance is better.	Distribution amplifier model specified (VM-4HN) is of Kramer make only.
4	2.5	21	Control System with IPAD2 as a touch panel	i)For using IPAD wireless access- 1 qty ; one wireless access point is required Also specify IPAD wireless brand ii) Clarify whether LAN network is to be provided.	i)One wireless access point is to be provided as per tender condition, IPAD wireless brand is Crestron ii)LAN network point will be provided by the port

SUB : "ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT"

Sl. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
5	2.3(iii) 2.3 (vi)e	19 20	<p>Biamp make Multichannel Amplifier with 8 Channel X 50W Power Amplifier for Ceiling speakers.</p> <p>Two Channel Zone Amplifier for speakers - Zone amplifier with power as 2X50W@4Ω & 2X25W@8Ω; frequency response of 20Hzto20kHz; THD<.3%; 1Unbalanced line input; Dynamic range is of 88 dB - Bose make - ZA250 LZ - 4 nos;</p>	<p>For ceiling speakers : Biamp make Multichannel Amplifier with 8 Channel X 50W Power Amplifier for Ceiling speakers - 1 qty. Bose dual channel amplifier – Bose make - ZA250 LZ - 4 nos mentioned. Bose amplifier PM 8250 – 1 qty ; 8 channel/250 watts recommended with Bose speakers instead of above four qty</p>	<p>Both Amplifier and Speaker shall be of BOSE make.</p>
6	2.5(b)	21	<p>For creating lighting scenes & controlling the lights in the room - Lighting controller - Crestron make - DIN-4DIMFLV4 - 1 nos;</p>	<p>control light dimming – when using Crestron - DIN-4DIMFLV4 , LED light fixing shall of 0-10V, with LED driver and of Mono LED</p>	<p>The Specification of lighting controller are as under DIN Rail 0-10V Dimmer Module DIN-4DIMFLV4 >4 channels of 0-10 Volt dimming control >Supports 120 and 220 to 240 Volt, 50/60 Hz applications. LED light fixing shall of 0-10V, with LED driver and of Mono LED is acceptable</p>
7	Section V (SI no:3)	52	<p>Providing and fixing of Wall paneling in Veneer with wood framework, 12mm Marine plywood surface and top layer of veneer with inlay of 6mm copper strip horizontally and vertically at interval of approx. 0.9m as per drawings and shade selected by architect and finishing with interior grade clear Polyurethane coat satin finish.</p>	<p>Kindly provide the approved brands for - plywood ,veneer</p>	<p>Plywood and Veener make:Euro Ply, Green ply or Timex ply-marine grade as per IS standards</p>

SUB : "ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT"

Sl. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
8	Section V (SI no:32)	59	Providing and fixing of 50 media range GSM 900/1200/1800 MHz CDMA/WSMA model TM-50 complete. Textel or equivalent make and Eubiq cable management system for meeting table.	i)Brand not given& Electrical strip make used on the table with model no ii)Mention model of Eubiq management	i)Make of electrical strips is Eubic, Model no: RH1 Profile and 600mm SFC3track complete with end caps and mounting clamps -3 nos ii)Eubiq make international adaptorsITL2- 6 nos
	Section V (SI no:32)	55	Providing and fixing of boat shape Conference table of size 7.5m x 2.4m top in combination of light and dark veneer over sub structure of marine grade plywood/block board and wood framework as per design including making necessary opening for mounting of power strips, boxes, microphones, sockets, etc and finished with asian paint Woodtech Polyester or equivalent coat having high gloss and heat resistance and hardness, etc. complete as per drawing and instruction of architect		
9	Section V (SI no:1)	51	Removing of existing floor carpet, wall paneling, false ceiling, electrical fixtures and conduits and glass windows and dismantling of existing table, to make the site ready for new work including handing over the reusable material to the client as per client's recommendation and suitably disposing off the balance material from the office premises. Carpet area of Room: 95sq. mts.	Scrap disposal not mentioned	Scrap should be disposed off from office premises as directed by Engineer in charge
10	Section V (SI no:2)	51	Providing and fixing laminated floor of pergo / square foot or equivalent make, Autumn oak shade as approved by architect including cleaning of the sub floor, leveling of floor and installation of 2mm thick polyurethane foam sub base for walking sound reduction, including all nexessart accessories like T profiles, L profiles, Skirting etc complete.	Floor tiles is to be removed	Providing and fixing laminated floor of pergo on existing tile floor after removing carpet as directed by Engineer in charge

SUB : "ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT "

Sl. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
11	Section V (SI no:4)	52	Providing and fixing of acoustic Wall paneling with acoustic board and fabric of Soundsoak , Amstrong or equivalent make mounted with wood or aluminum framework Marine plywood if required with inlay of 6mm copper strip horizontally and vertically as per drawings and as directed by the architect at an approximate interval of approx. 0.9m	i)What standard size wood paneling size used for the work ii)Brand of Fabric to be specified	i)Size is irrelevant as the same will be hidden by fabric. ii)Fabric should be Chenille fabric of Unitex.
12	Section V (SI no:35)	59	Replacing of existing AC grill with new grill and making necessary connection to existing AC ducts.	Clarify whether in the AC only grill change is required	As per tender condition only existing AC grill to be replaced with new grill appropriately directed to cause least discomfort to users as directed by Engineer in charge.
13	Section V (SI no:34)	59	Electrical rewiring of entire conference room including installation of new switches, 5 amps sockets,, MCB, distribution box, connection to existing earthing, connection to roman blind motors, as per IS standards using Anchor / Legrand or Schneider make switches sockets and accessories as per provided electrical layout complete.	i)Switches make not specified, ii)Complete electrical BOQ for the room – power points and switches etc	i)Switches make Anchor / Legrand or Schneider specified in tender condition. ii) Electrical rewiring of entire conference room including installation of – power points and switches etc shown in the electrical layout enclosed along with tender .
14	Section V (SI no:9)	52	Providing and fixing of 30 mm thick marine grade flushed doors double shutter of size 1675mm x 2000mm having both side veneer and 6 mm copper strip inlay as per drawing finished with interior grade clear PU coat and polish including godrej or equivalent make locks in brush chrome finish with SS hinges, door closers etc. complete as per design and direction of architect	Details for door fixing for the room	Paneling will have offset for door and door frame will anyway be covered by veneer.
15	Section V (SI no:3)	53	Providing and fixing of Wall paneling in Veneer with wood framework, 12mm Marine plywood surface and top layer of veneer with inlay of 6mm copper strip horizontally and vertically at interval of approx. 0.9m as per drawings and shade selected by architect and finishing with interior grade clear Polyurethane coat satin finish.	i) Interior decoration must be specific. ii)Approved Brands of the resin to be used	i)Detail Drawings and views enclosed with tender have required information ii)Polyurethane coat of Asian paint make

SUB : "ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT "

SI. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
16	Section V (SI no13)	54	Providing and fixing of 10 mm thick and 14" deep glass display shelf of approximate length of 3M as per drawing and direction of architect including all necessary fittings brackets etc. complete.	Table glass type - plain or toughened etc	Plain glass to be used
17	Section V (SI no21)	56	Artwork and accessories	More specification of the art work to be provided .- photo	A3 size reproduction prints of artworks created by Goan artist Mario Miranda- to be mounted on a 20mm brush aluminum frame having white mount board-paintings can be sourced from museum houses of Goa, Torda ,Bardes Goa, official custodian of Mario Miranda's art works as directed by Engineer in charge.
18	Section V (SI no 5)	52	Providing and fixing of acoustic false ceiling with silk Fabric including acoustic paneling framework and support complete as per fabric selected by architect and as per drawing and design provided by architect. Fabric should be fire retardant and comply Fire fighting norms as per NBC.	Details of the existing fire protection for providing the provision in wood work	There is only one smoke detector in the center of the ceiling. Fire protection system provision of 6 sensors should be made for future implementation by drawing the cables for the same so that the ceiling need not be dismantle later on.
19	Section V (SI no 23)	57	Providing and installing 1500mm tall Accent Floor lamp having metal support in SS finish and Fabric lamp shade as per design and drawing , fixing of Acrylic sign board with LED lighting having acrylic letters and logo including cutting and sticking and LED driver complete as multicolor as per design of size 5'x3'	Brand for the lamp- photo	Brand-Philips(Embarcadero 2 Light Floor Lamp)
20	Section V (SI no15)	55	Providing and installing of High back chair of featherlite make chrome Leatherette series or equivalent having leatherette for seat and back and chrome finished arms and base with casters etc. complete.	Chairs model nos and approved brands	Chair make: Featherlite , details adequately mentioned in specification

SUB : “ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT ”

Sl. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
21	2.4	20 & 21	<p>i)Video Conferencing Setup, Polycom make, model: Group 500-1080 with MP full HD with 1 Mic and Multipoint connectivity.</p> <p>ii)Providing and fixing video conferencing solution as per the following specification:</p> <p style="padding-left: 40px;">a) New VC Setup - High-definition video conferencing –with 1+3 Locations Multi Location Connectivity Licencemake :Peoplelink/Polycom/Avaya/Huawei</p>	<p>a) Whether (i) to be consider or ii(a) to be consider..</p> <p>b)Suggest hardware based VC for stable and jitter free performance over NIC network – Polycom/avaya</p>	<p>a)Only ii(a) of the tender condition to be considered,(i) therefore stands deleted</p> <p>b) Nic network is supported by polycom/Avaya/Huawei& tender condition prevails</p>
22	2.2(iv(c))	19	Multiple connectivity setup on the table includes power sockets, HDMI, VGA & LAN connectivity - Popup Box - Hydraulic Table interfaces, with HDMI, VGA, Power and LAN connections - Make Integrator	Whether single Popup box or multiple is required	Single Popup box is required
23	3.10	29	The work shall be completed within 6 weeks from 7 th day of issue of LOA.	Whether the completion period can be increased to 60days	Completion period of 60days is acceptable.
24	1.13(ii)	11	The bidder should posses a valid Service tax Registration Certificate, PAN, VAT, EPF registration and ESI registration number.	We have seven people working under us, is ESI applicable to us, please clarify	EPF/ ESI shall be applicable as MPT is the principal employer

SUB : "ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT"

SI. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
25	3.51	46 &47	<p>Payment shall be released on furnishing performance Bank Guarantee and signing the Agreement by the Bidder as per the following terms:</p> <p>i) 70% of payment shall be released against supply of materials at site in good condition.</p> <p>ii)20% of payment shall be released against successful installation, testing and commissioning of the work</p> <p>iii)Balance 10% of the payment will be released after taking over of the complete work.</p>	<p>i. Whether advance payment can be made to the party</p> <p>ii. Request to provide payment against the delivery of the material</p>	<p>i) Advance payment is not acceptable, tender condition prevails.</p>
26	1.16(c)	14	<p>The price offered should be firm and inclusive of all taxes & duties with WCT and Service Tax extra as applicable.</p>	<p>Bill deduction against the work executed – against WCT , service tax and TDS</p>	<p>Tender condition prevails. However WCT, Service Tax & TDS are applicable at prevailing rates.</p>
27	3.14(ii)	30	<p>Security deposit shall consist of two parts:</p> <p>a) A Bank Guarantee equivalent to 5% of the contract value rounded off to nearest 100 rupees, shall be submitted within 30 days of issue of Letter of Acceptance</p> <p>b) The balance 5 % shall be recovered as Retention Money from the running bills. Thereafter, the total of 10% (BG 5% and 5 % Retention money) shall be returned after completion of Guarantee period of 1 year.</p>	<p>Whether BG equivalent to 10 % of contract value can be submitted instead of 5 % deduction as retention money from running bills</p>	<p>Acceptable. SD at 10% of contract value in the form of BG.</p>
28				<p>Request for storage facility of material</p>	<p>Storage facility for material will be provided free of cost</p>

SUB : "ESTABLISHMENT OF CRUISE FACILITATION CENTRE CUM BOARD ROOM AT ADMINISTRATIVE BUILDING, MPT "

SI. No.	CLAUSE NO.	PAGE NO.	TENDER CONDITION	BIDDER QUERIES	CLARIFICATION
29	1.5.1	7	Note 2: Back to back support from the system integrated for audio visual system.	Whether the Authentication letter for back to back support from BOSE should be from OEM or Distributor	The tenderer should submit manufacturers authorization letter from the OEM addressed to Port with special reference to this tender for the following 1)Video Projector- Hitachi 2)Audio system- Bose 3)Video Conferencing-Peoplelink / Plycom / Avaya / Huawei. 4) Control System: Crestron, Model CP3. Further manufacturers guarantee/warranty for period of two years shall be also indicated in the authorization letter.
30	1.8	8	The Bidder shall furnish as part of its Tender, an EMD of Rs. 73,785/- (Rupees Seventy Three Thousand Seven hundred and Eighty Five Only). <u>Tender without EMD shall be treated invalid.</u> The E.M.D. shall be submitted in the form of Demand draft drawn in favour of FA & CAO, Mormugao Port Trust, VASCO, from any Nationalized/Scheduled Bank, having its branch at VASCO.	Can we submit EMD in form of BG?	As per the tender condition ,EMD is to be submitted in the form of DD only